



Village of Woodridge

Community Development Department • Five Plaza Drive • Woodridge, IL 60517-5014
(630) 719-4750 • FAX (630) 719-2900

Water and Sewer Guidelines

WATER

- Minimum 1-1/2" diameter on all new construction
- Type "K" copper or ductile iron
- Continuous line without splices
- No sweated joints on street side of meter
- All fittings must be flared; compression fittings may be used on repairs only
- Valves must be full flow - ball valves only
- Installed 10'-0" from sewer or shelved 18" up and over
- Minimum burial depth 4'-0"
- Line must be pressurized for inspection
- If removing a tap or relocating a tap the unused tap to main must be removed, including corp and a stainless steel repair sleeve installed over abandon connection.
- All items above must be inspected prior to backfill.

SEWER

- Through foundation wall – 4" Min; Schedule 40 PVC, ductile or cast iron.
- PVC used for service line must be SDR 26, 6" minimum diameter
- Minimum bed and cover of 4" CA-7 gravel
- Line must slope away from building
- Minimum burial depth 4'-0"
- Connection to main must be 6" diameter, minimum, and be made by a wye fitting with an angle of 30-45 degrees. No punch in connections allowed
- Joints must be made by the following means: push-in gaskets, "no-shear" mission couplings.
- Clean-outs must be installed with sanitary tee
- If removing a tap or relocating a tap the unused tap to main must be removed entirely and the section of main must be replaced with no shear mission couplings.
- All items above must be inspected prior to backfill.

NOTE:

- Call for inspection after sewer & water installations are complete, water line is pressurized, and the sewer is properly bedded. Leave connections visible for inspection.
- Restoration of the R.O.W. is required within 2 weeks of the repair, weather permitting and is the responsibility of the contractor. A pre-pour inspection is required for public walk replacement. Walks to be backfilled with CA-7 gravel (Washed ¾", no fines) and be poured at a 4" thickness.
- Remember to protect the hole if it must be kept open overnight
- A clean-out shall be located within 5 feet of the building foundation, either on the inside or the outside of the building.
- Call for final inspection after all sidewalks have been replaced and the yard has been restored.
- Sewer and water excavations on private property shall be compacted, leveled and restored to natural grade within six (6) months of the date of the issuance of the permit. (Ord. 2006-17, 4-20-2006)

FOR LOCATION OF UTILITIES CONTACT J.U.L.I.E AT 1-800-892-0123

VILLAGE OF WOODRIDGE BUILDING PERMIT

5 Plaza Drive
 Woodridge, IL 60517
 Phone: (630) 719-4750 Fax: (630) 719-2900

Plan # or Name _____ Date _____

Permit Application Address _____

Lot# _____ Subdivision _____

Description of Work _____

Zoning _____ Size of Lot _____ X _____ Total Estimated Cost \$ _____

Property Owner _____ Address, Town, Zip _____ Phone _____

Tenant _____

General Contractor _____

Architect _____

Brick _____

Carpenter _____

Concrete/ Asphalt Contractor _____

Electrician _____

Low Voltage Contractor _____

Excavator _____

Fire Alarm _____

Fire Protection _____

Heating Contractor _____

Plumber _____

Roofer _____

Sewer Contractor _____

Kind of Construction _____ Width _____ Length _____ Height _____

Contact Email Address _____ Applicant's Signature _____

Permit # _____

APPROVED

Plan Review _____ Date _____

ISSUED

Plan Review _____ Date _____

ACCOUNTING CODE	AMOUNT
101-0000-323-0100	Building Permit
	Electrical Permit
	Plumbing Permit
	Plan Reviews
	Deck Permit
	Driveway Permit
	Fence Permit
	Flatwork Permit
	Lawn Sprinkler
	Sewer Permit
	Shed Permit
	Swimming Pool
	Roof Permit
	Misc.
501-0000-344-0500	Water Connection
501-0000-344-0600	Water Meter
501-0000-344-0200	Unmetered Water
	School District
101-0000-207-1100	School Dist. 66
101-0000-207-1200	School Dist. 68
101-0000-207-1300	School Dist. 99
101-0000-207-1412	School Dist 113A
101-0000-207-1701	School Dist 203
101-0000-207-1500	School Dist 210
101-0000-207-19XX	School Dist 365
	Park District
101-0000-207-16XX	Woodridge Park District
101-0000-207-20XX	Bolingbrook Park Dist
206-0000-365-0000	Charitable Contributions
	GRAND TOTAL

OFFICE USE ONLY